

Measurement of fluid flow in closed conduits —

Part 2: Velocity area methods —

Section 2.2 Method of measurement of velocity at one point of a conduit of circular cross section

[ISO title: Determination of flowrate of fluids in closed conduits
of circular cross-section — Method of velocity measurement at
one point of the cross-section]

UDC 532.542:532.574:621.643.2-462.311

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Industrial-process Measurement and Control Standards Committee (PCL/-) to Technical Committee PCL/2 upon which the following bodies were represented:

British Compressed Air Society
 British Gas Corporation
 British Industrial Measuring and Control Apparatus Manufacturers' Association (BEAMA)
 Department of Energy (Gas Standards)
 Department of Industry (National Engineering Laboratory)
 Department of Trade (Consumer Safety Unit, CS Division)
 Department of Trade (National Weights and Measures Laboratory)
 Electricity Supply Industry in England and Wales
 Energy Industries Council
 Institute of Measurement and Control
 Institute of Petroleum
 Institute of Trading Standards Administration
 Institution of Gas Engineers
 National Water Council
 Society of Chemical Industry
 United Kingdom Atomic Energy Authority
 Coopted member

The following bodies were also represented in the drafting of the standard, through subcommittees and panels:

Fan Manufacturers' Association
 Hevac Association
 National Coal Board
 Scientific Instrument Manufacturers' Association (BEAMA)

This British Standard, having been prepared under the direction of the Industrial-process Measurement and Control Standards Committee, was published under the authority of the Board of BSI and comes into effect on 31 August 1983

© BSI 07-1999

The following BSI references relate to the work on this standard:
 Committee reference PCL/2
 Draft for comment 81/25553 DC

Amendments issued since publication

Amd. No.	Date of issue	Comments

ISBN 0 580 13383 4

Contents

	Page
Committees responsible	Inside front cover
National foreword	ii
<hr/>	
1 Scope and field of application	1
2 Symbols and definitions	1
3 Principle	3
4 Procedure	4
5 Uncertainties of measurement	6
<hr/>	
Annex A Determination of the transverse velocity gradient at the point of mean axial velocity	11
Annex B Example of calculation of the uncertainty of a flow measurement when the primary device is placed at the point of mean axial velocity	11
Annex C Example of calculation of the uncertainty of a flow measurement when the primary device is placed on the axis of the conduit	12
Publications referred to	Inside back cover

National foreword

This British Standard has been prepared under the direction of the Industrial-process Measurement and Control Standards Committee and is identical with ISO 7145:1982 “*Determination of flowrate of fluids in closed conduits of circular cross-section — Method of velocity measurement at one point of the cross-section*”, published by the International Organization for Standardization (ISO).

Terminology and conventions. The text of the international standard has been approved as suitable for publication as a British Standard without deviation. Some terminology and certain conventions are not identical with those used in British Standards; attention is drawn especially to the following.

The comma has been used as a decimal marker. In British Standards it is current practice to use a full point on the baseline as the decimal marker.

Wherever the words “International Standard” appear, referring to this standard, they should be read as “British Standard”.

Cross-references

International standard	Corresponding British Standard
ISO 4006:1977	BS 5875:1980 <i>Glossary of terms and symbols for measurement of fluid flow in closed conduits</i> (Identical)
ISO 5168:1978	BS 5844:1980 <i>Methods of measurement of fluid flow: estimation of uncertainty of a flowrate measurement</i> (Identical)

The Technical Committee has reviewed the provisions of ISO 3354 and ISO 3966, to which reference is made in the text and for which there are no corresponding British Standards, and has decided that they are acceptable for use in conjunction with this standard.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, pages 1 to 14, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

1 Scope and field of application

1.1 Scope

This International Standard specifies a method for the determination of the volume rate of flow of a single phase fluid of a substantially constant density (Mach number $\leq 0,25$) under steady fully developed flow conditions in a closed conduit of circular cross-section running full by measurement of the flow velocity in a single point.

The method provides for the possibility of placing the primary velocity measuring device either at the point where it is assumed the mean axial velocity prevails, i.e. at a distance of $0,242 R$ from the wall of the conduit (R being the radius of the conduit), or on the axis of the conduit.

If there are doubts about the symmetry of the flow it is advisable to use at least two measuring points located symmetrically on one circumference at the distance from the wall specified above.

1.2 Field of application

The method specified in this International Standard does not apply unless the following conditions have been fulfilled:

a) The conduit shall have a straight length sufficiently long so that, in the measuring section, a distribution of velocities corresponding to fully developed turbulent flow can be observed (see 2.3.5).

Hydraulic resistance coefficient λ of the conduit should not exceed 0,06.

b) The flow must be turbulent and the Reynolds number, Re_D should exceed or be equal to the following values:

λ	$\geq 0,03$	0,025	0,02	0,01
Re_D	10^4	3×10^4	10^5	10^6

When the velocity is measured on the conduit axis, the flow should be in fully rough turbulent regime (see 2.3.6). The Reynolds number, Re_D , should then exceed or be equal to:

λ	0,06	0,05	0,04	0,03	0,025	0,02	0,01
Re_D	3×10^4	5×10^4	10^5	3×10^5	5×10^5	10^6	5×10^7

c) The experimental data on which this International Standard is based principally relate to conduits of diameter equal to or greater than 300 mm, but there is every reason to believe that the method can be applied to conduits of smaller diameter.

d) In any point of the measuring cross-section, the angle between the direction of local velocity and the axis should not exceed 5° .

This condition can be verified either with the probe used for the measurements, if the design permits this, or with a different type of probe. It can be assumed that if the condition required is verified for a given flow q , then this condition is also met within the range $q/3$ to $3q$.

1.3 Accuracy of the method

As a guide, it can be considered that determination of flow from velocity measurement at a single point, carried out in accordance with the requirements of this International Standard, will lead to an uncertainty (at a confidence level of 95 %) not exceeding ± 3 %. However, the uncertainty on the flow shall be calculated for each individual application of this International Standard depending on the type of primary device, on the method of use and if necessary, on the method of calibration as well as on the measuring conditions.

2 Symbols and definitions

2.1 References

The vocabulary and symbols used in this International Standard are defined in the following International Standards:

ISO 3354, *Measurement of clean water flow in closed conduits — Velocity-area method using current-meters.*

ISO 3966, *Measurement of fluid flow in closed conduits — Velocity-area method using pitot-static tubes.*

ISO 4006, *Measurement of flow of fluids in closed conduits — Vocabulary and symbols.*

ISO 5168, *Measurement of fluid flow — Estimation of uncertainty of a flow-rate measurement.*

The definitions appearing in 2.3 are given only for terms used in a special sense for which it would seem useful to repeat the definition of meaning.

2.2 Symbols

Symbol	Quantity	Dimensions ^a	SI units
A	Area of the cross-section of the conduit	L^2	m^2
a	Height of any high spot or protrusion on the external wall of the conduit	L	m
D	Diameter of the conduit	L	m
d	Diameter of the active part of the primary device	L	m
e	Uncertainty, as an absolute value	b	b
E	Uncertainty, as a relative value	—	—
k	Uniform equivalent roughness	L	m
P	External perimeter of the conduit	L	m
q_V	Volume flow rate	L^3T^{-1}	m^3/s
R	Radius of the conduit	L	m
Re_D	Reynolds number, $Re_D = \frac{UD}{\nu}$	—	—
s	Standard deviation	b	b
U	Mean axial velocity	LT^{-1}	m/s
u^*	Friction velocity, $u^* = U \sqrt{\frac{\lambda}{8}}$	LT^{-1}	m/s
v	Local fluid velocity	LT^{-1}	m/s
v_0	Local velocity at centre of conduit	LT^{-1}	m/s
v^*	Local non dimensional velocity, $v^* = \frac{v}{U}$	—	—
y	Distance from one measurement point to the wall	L	m
y^*	Non dimensional distance from one measurement point to the wall, $y^* = \frac{y}{R}$	—	—
λ	Universal coefficient of head loss as defined by the formula $\Delta p = \lambda \frac{L}{D} \times \frac{1}{2} \rho U^2$ where Δp is the pressure drop on the tube length L and ρ is the fluid density	—	—
ν	Kinematic viscosity of the fluid	L^2T^{-1}	m^2/s

^a L = length, T = time
^b The dimensions and units are those of the quantity to which the symbol refers, and which will be indicated by an index.

2.3 Definitions

2.3.1

primary velocity measuring device

any device that changes a local flow velocity into a physical quantity suitable for measurement (for example, differential pressure, frequency of an electric signal, etc.)

NOTE Throughout the rest of this document, the expression "primary device" is used instead of "primary velocity measurement device".

2.3.2

measuring point

any point where the local velocity of the flow is measured

2.3.3

mean axial velocity

ratio of the volumetric flowrate and the area of the measuring section

$$U = \frac{q_V}{A}$$

2.3.4

point of mean axial velocity

in a cross-section of the conduit this is a point where the local velocity of the flow is equal to the mean axial velocity

2.3.5

fully developed flow

the flow in which the distribution of velocities does not change from one cross-section to another. It is generally obtained at the outlet of a straight length of conduit of sufficient length (see 4.1)

2.3.6

fully rough turbulent flow

in a conduit of given relative roughness, this occurs when the hydraulic resistance coefficient is independent of the Reynolds number and may be assumed to be present when

$$Re_D > 500 \times 10^{\frac{1}{2\sqrt{\lambda}}}$$

or

$$Re_D > 1\,850 \frac{D}{K}$$

3 Principle

3.1 General

The principle of the determination of flow by measurement of the local velocity at a single point is based on the existence of laws applicable to all conduits, provided that all parameters remain within the limits indicated in 1.2, which relate the value of the local velocity at a given point in the cross-section to the value of the mean axial velocity in this section.

Two variants on this method, which differ in the position of the measuring point, are described in 3.2 and 3.3. It should however be emphasized that these two methods are not equivalent as the second one requires previous calibrations.

3.2 Measurement at the point of mean axial velocity

From a large number of experimental results it has been possible to establish that under turbulent conditions and within the limits indicated in 1.2 the position of the circle centred on the pipe axis at which the local velocity is equal to the mean axial velocity remains fixed as the flowrate changes, and is the same for any pipe. This circle is at a distance from the wall $y_1 = (0,242 \pm 0,013) R$, R being the radius of the cross-section.

The principle of the method therefore consists of:

- a) Selecting a measurement cross-section (see 4.1).
- b) Measuring the dimensions of this cross-section in order to obtain its area A (see 4.2).
- c) Selecting, at the above-mentioned distance y_1 from the wall, the point of measurement of velocity (see 4.4.1).
- d) Measuring the local velocity v_1 of the flow, according to the special conditions required by the primary device used (see 4.3).
- e) Calculating the volume rate of flow equal to the product of the cross-sectional area and the measured velocity (v_1) taken as being the mean axial velocity (U):

$$q_V = A \times U = A \times v_1$$
- f) Determining the uncertainty associated with this flow measurement (see clause 5).

3.3 Measurement on the axis of the conduit

If the above method cannot be applied, the local velocity of the flow can be measured at the centre of the measurement cross-section on the axis of the conduit. However, it is then necessary to carry out calibrations by previous determination of the ratio U/v_0 of the mean axial velocity at the velocity at the centre. This ratio remains approximately constant for a given pipe in fully rough turbulent conditions.

The principle of the method therefore consists of:

- a) Selecting a measurement cross-section (see 4.1).
- b) Measuring the dimensions of this cross-section in order to obtain its area A (see 4.2).
- c) Measuring the local velocity of flow at the centre of the cross-section v_0 , in accordance with the special conditions required by the primary device used (see 4.3).
- d) Calculating the mean axial velocity U by multiplying the velocity measured at centre v_0 by the previously determined calibration coefficient (see 4.4.2).
- e) Calculating the volume rate of flow equal to the product of the cross-sectional area and the mean axial velocity:

$$q_V = A \times U = A \times v_0 \times \frac{U}{v_0}$$

- f) Determining the uncertainty associated with this flow measurement (see section 5).

4 Procedure

4.1 Selection of the measurement cross-section

The measurement cross-section shall be situated on a straight length of the conduit. In order to have the best chance of a fully developed flow, the length of the straight section upstream from the measurement cross-section shall be as large as possible and in all cases at least equal to the values specified in the table below:

Type of disturbance upstream from the measuring cross-section	Minimum upstream straight length ^a	
	For a measurement at the point of mean axial velocity	For a measurement on the axis of the conduit
90° elbow or a t-bend	50	25
Several 90° coplanar bends	50	25
Several 90° non-coplanar bends	80	50
Total angle con-vergent 18 to 36°	30	10
Total angle divergent 14 to 28°	55	25
Fully opened butterfly valve	45	25
Fully opened plug valve	30	15

^a Expressed in multiples of the diameter of the conduit.

Downstream from the measurement cross-section, the straight length shall be at least equal to five duct diameters whatever the type of disturbance.

4.2 Determination of the area of the measurement cross-section

4.2.1 Calculation of the area from the mean diameter

Normally the area of the measurement cross-section shall be calculated from the mean diameter of the conduit which is taken to be equal to the arithmetic mean of measurements made on four diameters of the cross-section at approximately equal angles to each other. If the difference between the length of two consecutive diameters is greater than 0,5 %, the number of diameters measured shall be doubled.

4.2.2 Calculation of the area from the perimeter

If there is no possibility of directly measuring the inside diameter of the conduit, it is allowed to determine the area of the measurement cross-section by measuring the external perimeter P if necessary corrected with ΔP defined below while taking account of the thickness of the wall e , from the equation:

$$A = \frac{\pi}{4} \left(\frac{P - \Delta P}{\pi} - 2e \right)^2$$

If this method is used, the external surface of the conduit shall have any roughness carefully removed. If there are any local highspots such as welding beads, a correction ΔP calculated for each highspot from the following formula is subtracted from the measured value for the perimeter:

$$\Delta P = \frac{8}{3} a \sqrt{\frac{a}{D}}$$

where a is the height of the highspot.

This method cannot be used when the number and position of the protrusions does not allow the measuring tape to contact the spaces between the protrusions or when the height of any protrusion exceeds 1 % of the pipe diameter.

4.3 Specifications regarding the primary device

4.3.1 Choice of the primary device and its support

The primary device shall be chosen taking account of the properties of the fluid measured and the possible presence of matter in solution or suspension. The method of fixing shall be examined taking into account the possible interference between the support and primary device (effects on calibration, blockage effect), and in order that there is no likelihood of vibration throughout the range of flows being considered.

The primary device will normally be a current-meter or pitot-static tube; in these cases it shall be installed and used in accordance with the requirements of the appropriate standard (ISO 3354 and ISO 3966 respectively) unless specific relaxations are permitted in this International Standard. Other primary devices for measuring local velocity cannot be used unless it has been verified that they are completely satisfactory for the measuring conditions by means of a calibration carried out either in situ or in similar flow and installation conditions. This calibration must permit an uncertainty of no greater than ± 1 % in the local velocity measurements.

4.3.2 Dimensional limitations

The effects of the transverse gradient of velocities and the blockage effect due to the primary device and its support result in dimensional limitations in the equipment used.

In the case of a pitot tube placed at the point of mean axial velocity, the ratio between the diameter of the head and the diameter of the conduit shall not exceed 0,02. If the pitot tube is placed on the axis of the conduit, this ratio may, if necessary, rise to 0,06.

In the case of a current meter, the ratio between the diameter of the propeller and the diameter of the conduit shall not exceed 0,11 whatever the position of measurement.

4.4 Determination of the mean axial velocity

The local velocity measurements and the corrections applied to them must be carried out in accordance with the relevant International Standard for the primary device used.

4.4.1 Measurement at the point of mean axial velocity

Wherever possible, and in particular if the indication given by the primary device is unaffected by the transverse gradient of velocities and if the straight length available upstream of the measuring plane is sufficient, the measurement shall be made at a point where the local velocity is assumed to be equal to the mean axial velocity.

For this purpose, the primary device shall be installed at a distance of $0,242 R$ from the internal wall of the conduit with a tolerance of less than $\pm 0,01 R$, this distance being calculated with respect to the diameter on which the primary device is installed and not with respect to the mean diameter of the conduit.

4.4.2 Measurement on the axis of the conduit

If the primary device does not provide the required accuracy in view of the transverse gradient of velocities, or if its dimensions do not satisfy the requirements of 4.3.2 for a measurement at the point of mean axial velocity, or again if the straight length available is between the values appearing respectively in the two columns of the table in 4.1, it is still possible to measure the flow by placing the primary device on the axis of the conduit. However, it is then necessary to carry out calibrations by previously determining the ratio of the mean axial velocity to the velocity at the centre.

This ratio in principle remains constant throughout the entire area of rough turbulent conditions. It is however recommended, wherever possible, to verify it by carrying out this calibration for two or three conditions that differ as widely as possible and covering the range of flows considered.

Calibration can be obtained either by measuring the velocity at the point of mean axial velocity as indicated in 4.4.1 or by using any other standard method of measuring flowrate which has an uncertainty of less than $\pm 2\%$. The accuracy of the subsequent flow measurements will depend directly on the accuracy of the method of flow measurement used for calibration purposes.

NOTE Calibration by measurement at the point of mean axial velocity is not possible unless the straight length upstream is greater than the values given in the first column of the table in 4.1.

5 Uncertainties of measurement

This clause defines certain types of fundamental statistical terms used in this International Standard and specifies the method to be used in evaluating the uncertainty of the measurement of a volume rate of flow from the list of sources of error that might occur when measuring the local velocity and calculating the flow.

Annex B and Annex C give examples of calculating the overall uncertainty, their sole purpose being to illustrate the method of calculation set out below, and which are not meant to provide standard values for the various uncertainties, in this respect each individual case must be the subject of a careful study.

5.1 Definition of standard deviation¹⁾

5.1.1 If a variable X is measured several times, each measurement being independent of the others, the standard deviation s_x of the distribution of n measurements X_i is estimated by:

$$s_x = \left[\frac{\sum_{i=1}^n (\bar{X} - X_i)^2}{n - 1} \right]^{1/2}$$

where

\bar{X} is the arithmetic mean of n measurements of the variable X ;

X_i is the value obtained for the i th measurement of the variable X ;

n is the total number of measurements of X .

For brevity, s_x is normally referred to as the standard deviation of X .

5.1.2 If several measurements of the variable X are not available or if these measurements are too few to allow direct calculation of the standard deviation on a statistical basis, and if the range within which the measurements lie is known, the standard deviation may be taken as one quarter of the range.

¹⁾ The standard deviation defined here is what statisticians more accurately call the "estimation of standard deviation".

5.2 Propagation of errors

Let X_1, X_2, \dots, X_k be the various independent quantities which when known permit calculation of the flow q_V ; this can be expressed as a given function of these variables:

$$q_V = f(X_1, X_2, \dots, X_k)$$

Let s_1, s_2, \dots, s_k be the estimations of the standard deviations on the quantities X_1, X_2, \dots, X_k ; an estimation of the standard deviation s_{q_V} of the flowrate measurement is given by:

$$s_{q_V} = \left[\left(\frac{\partial q_V}{\partial X_1} s_1 \right)^2 + \left(\frac{\partial q_V}{\partial X_2} s_2 \right)^2 + \dots + \left(\frac{\partial q_V}{\partial X_k} s_k \right)^2 \right]^{1/2}$$

where $\frac{\partial q_V}{\partial X_1}, \frac{\partial q_V}{\partial X_2}, \dots, \frac{\partial q_V}{\partial X_k}$ are partial derivatives.

5.3 Definition of uncertainty

5.3.1 Within the meaning of this International Standard, the uncertainty on the measurement of a variable is defined as twice the standard deviation of this variable. The uncertainty shall be calculated and presented under this designation in any measurement claimed to be in accordance with this International Standard.

5.3.2 If the component uncertainties whose combination provides the uncertainty are independent of each other, small and numerous and have a gaussian distribution, there is a probability of 0,95 that the true value of the error is less than the uncertainty.

5.3.3 When the standard deviation s_{q_V} of the flow measurement q_V has been evaluated, the uncertainty e_{q_V} is given by:

$$e_{q_V} = \pm 2 s_{q_V}$$

The relative uncertainty, E_{q_V} , is defined by:

$$E_{q_V} = \frac{e_{q_V}}{q_V} = \pm 2 \frac{s_{q_V}}{q_V}$$

Any flowrate measurement, q , shall be reported in one of the following forms:

- a) Uncertainties expressed in absolute terms
- 1) Flowrate q = ...
 - Random uncertainty $(e_R)_{95}$ = ...
 - Systematic uncertainty e_s = ...
 - Uncertainties calculated in accordance with ISO 5168.
 - 2) Flowrate q = ...
 - (Combined) uncertainty $\sqrt{(e_R)_{95}^2 + e_s^2}$ = ...
 - Random uncertainty $(e_R)_{95}$ = ...
 - Uncertainties calculated in accordance with ISO 5168.

- b) Uncertainties expressed in percentage terms
- 1) Flowrate q = ...
 - Random uncertainty $(E_R)_{95}$ = ... %
 - Systematic uncertainty E_s = ... %
 - Uncertainties calculated in accordance with ISO 5168.
 - 2) Flowrate q = ...
 - (Combined) uncertainty $\sqrt{(E_R)_{95}^2 + E_s^2}$ = ... %
 - Random uncertainty $(E_R)_{95}$ = ... %
 - Uncertainties calculated in accordance with ISO 5168.

5.4 Component uncertainties in the determination of the flow

During a measurement of flow carried out in accordance with this International Standard, the component uncertainties that may appear, depending on the method used, are as follows:

- In the case of a measurement at the point of mean axial velocity and a measurement on the axis of the conduit:
 - a) uncertainty on the area of the measurement cross-section;
 - b) uncertainty on the measurement of local velocity.
- In the case of a measurement at the point of mean axial velocity only:
 - c) uncertainty due to determination of the point of measurement;
 - d) uncertainty in the installation of the primary device at this point.
- In the case of a measurement on the axis of the conduit only:
 - e) uncertainty in the determination of the ratio of the mean axial velocity to the velocity at the centre.

5.4.1 Uncertainty on the area of the measurement cross-section

This uncertainty depends on the choice of method of measurement (average of several internal diameters directly measured or measurement of the external perimeter and the thickness of the wall) and the equipment used.

5.4.2 Uncertainty on the measurement of local velocity

This uncertainty depends on the type of primary device used, its conditions of use and the flow characteristics. In addition to following the manufacturer's instructions and the results of calibration, when the primary device is a current meter or a standard pitot tube reference is made to ISO 3354 or ISO 3966 respectively.

5.4.3 Uncertainty due to the determination of point of measurement

If the measurement is made at the point assumed to be the mean axial velocity, this uncertainty is determined by the dispersion of the experimental data that permitted the location in the measurement cross-section where the local velocity is equal to the mean axial velocity to be established. According to the data used as a basis in establishing this International Standard, standard deviation of the distance y^* (in a non-dimensional form) of this point to the wall is:

$$(s_1)_{y^*} = 0,0067$$

This uncertainty introduces an error on the flow which depends on the velocity gradient along the radius at the point considered. Annex A provides information on the determination of this gradient.

If the measurement is made on the axis of the conduit, this error does not occur.

5.4.4 Uncertainty due to the installation of the primary device

If the measurement is made at the assumed point of mean axial velocity, the uncertainty introduced by installing the primary device at the point prescribed by this International Standard depends on the assembly and inspection procedures followed.

It introduces an error in the flowrate measurement which, as in the previous case, depends on the velocity gradient.

If the measurement is made on the axis of the conduit, in the proximity of which the transverse velocity gradient is practically nul, this uncertainty is negligible.

5.4.5 *Uncertainty due to the determination of the ratio of the mean axial velocity to the velocity at the centre*

This uncertainty itself consists of the uncertainties made on each of the two terms of the ratio when calibrating the cross-section:

- the uncertainty on the mean axial velocity which depends on the method of flow measurement used and shall therefore be calculated according to the particular International Standards for this method;
- the uncertainty on the velocity at the centre which is most usually, but not always equal to the uncertainty described in 5.4.2; it may in fact happen that during calibration a more accurate device for measuring the local velocity than that installed for the subsequent measurements is used.

There may in addition also be a supplementary component uncertainty due to the possible non-constancy, depending on the flow, of the ratio of the mean axial velocity to the velocity at the centre, but this source of error is not taken into account within the context of this International Standard.

5.5 Calculation of the uncertainty on the flow measurement

The standard deviation associated with a flow measurement is obtained by combining the standard deviations of the uncertainties obtained from the various sources described in 5.4. Some of these uncertainties are random, others are systematic, and others again are themselves composed of component uncertainties some random, some systematic. However the probability of the distribution of the possible values of each systematic component is basically gaussian. The combination of random and systematic uncertainties may therefore be considered as if they were all in effect random.

5.5.1 *Case where the velocity is measured at the point of mean axial velocity*

According to the formulae in 5.2 and 5.3, the uncertainty, at a confidence level of 95 %, on the flow measurement is taken to be equal to twice the standard deviation s_{q_V} . The result of the flow measurement is therefore:

$$q_V \left[1 \pm 2 \sqrt{\left(\frac{s_V}{V}\right)^2 + \left(\frac{s_A}{A}\right)^2 + \left(\frac{dv^*}{dy^*} s_{1y^*}\right)^2 + \left(\frac{dv^*}{dy^*} s_{2y^*}\right)^2} \right]$$

$$= q_V \left(1 \pm 2 \frac{s_{q_V}}{q_V} \right)$$

where

- s_V is the standard deviation of the measure of the local velocity;
- s_A is the standard deviation of the measure of the area of the cross-section;
- s_{1y^*} is the standard deviation due to the determination of the point of mean axial velocity;
- s_{2y^*} is the standard deviation due to the error in installing the primary device;
- s_{q_V} is the resulting standard deviation on the flow measurement.

According to the information in Annex A, the velocity gradient value $\frac{dv^*}{dy^*}$ at the point of mean axial velocity

$y^* = 0,242$ can be taken to be equal to $3,7\sqrt{\lambda}$. If the coefficient λ of the conduit is not known precisely, a higher value is taken.

5.5.2 Case where the velocity is measured on the axis of the conduit

Similarly, the result of the measurement in this case is:

$$q_v \left[1 \pm 2 \sqrt{\left(\frac{s_v}{v}\right)^2 + \left(\frac{s_A}{A}\right)^2 + \left(\frac{s_U}{U}\right)^2 + \left(\frac{s_{v_0}}{v_0}\right)^2} \right]$$

$$= q_v \left(1 \pm 2 \frac{s_{q_v}}{q_v} \right)$$

where

s_U is the standard deviation of the mean axial velocity during calibration of the cross-section;

s_{v_0} is the standard deviation of the velocity at the centre during calibration of the cross-section.

Annex A Determination of the transverse velocity gradient at the point of mean axial velocity

In the region of the point of mean axial velocity, the logarithmic law describing the velocity distribution along a radius can be used to determine the approximate magnitude of the transverse velocity gradient.

This law is as follows:

$$\frac{v_0 - v}{u^*} = 2,5 \ln \frac{R}{y}$$

where u^* is the friction velocity (Prandtl-Von Karman theory)

$$u^* = U \sqrt{\frac{\lambda}{8}}$$

By making $v^* = \frac{v}{U}$ and $y^* = \frac{y}{R}$, the nondimensional velocity can be expressed in the form:

$$v^* = v_0^* + 2,5 \sqrt{\frac{\lambda}{8}} \ln y^*$$

The velocity gradient can therefore be expressed as:

$$\frac{dv^*}{dy^*} = 2,5 \sqrt{\frac{\lambda}{8}} \times \frac{1}{y^*}$$

By applying this formula to the point of mean axial velocity, for which $y_1^* = 0,242$, we obtain:

$$\frac{dv^*}{dy_1^*} = 3,7 \sqrt{\lambda}$$

Annex B Example of calculation of the uncertainty of a flow measurement when the primary device is placed at the point of mean axial velocity

(This annex does not form part of the standard.)

The calculation below is an example based on evaluations of various uncertainties in a flow measurement carried out under conditions that can be qualified as being normal. The values used are only given for information purposes and can in no case be used as standard values.

In the following example, it is assumed that the primary device is a pitot static tube designed and used in accordance with the specifications of ISO 3966:

— Standard deviation on the measurement of local velocity: in the example of calculation given in Annex G to ISO 3966, the following was obtained:

$$\frac{s_v}{V} = 0,007$$

— Standard deviation of the error on the measurement of area:

$$\frac{s_A}{A} = 0,004$$

— Standard deviation due to the determination of the point of mean axial velocity according to the information in 5.4.3:

$$s_{1y^*} = 0,0067$$

- Standard deviation due to the installation of primary device:

$$s_{2,y^*} = 0,01$$

- Velocity gradient: in a conduit where $\lambda = 0,03$, we obtain according to the formula given in 5.5.1:

$$\frac{dv^*}{dy^*} = 64$$

The standard deviation on the measurement of flowrate is therefore:

$$\frac{s_{q_V}}{q_V} = \sqrt{7^2 + 4^2 + (0,64 \times 6,7)^2 + (0,64 \times 10)^2} \times 10^{-3} = 0,011$$

and the flowrate will therefore be determined with an uncertainty, at a confidence level of 95 %, of:

$$E_{q_V} = \pm 2 \frac{s_{q_V}}{q_V} = \pm 2,2 \%$$

The value thus obtained serves to illustrate that the uncertainty on a flow measurement made in accordance with this International Standard with the primary device placed at the point of mean axial velocity is normally less than $\pm 3 \%$.

Annex C Example of calculation of the uncertainty of a flow measurement when the primary device is placed on the axis of the conduit

(This annex does not form part of the standard.)

The calculation below is an example based on evaluations of various uncertainties in a flow measurement carried out under conditions that can be qualified as being normal. The values used are only given for information purposes and can in no case be used as standard values.

In the following examples, it is assumed that the primary device is a pitot static tube designed and used in accordance with the specifications of ISO 3966.

C.1 Calibration by the velocity area method using pitot static tubes

- Standard deviation on the measurement of local velocity: as in Annex B, we will make:

$$\frac{s_v}{v} = 0,007$$

- Standard deviation of the error on the measurement of the area: as in Annex B, we will make:

$$\frac{s_A}{A} = 0,004$$

- Standard deviation of the mean axial velocity during calibration: for a measurement made in accordance with ISO 3966, we will for example have:

$$\frac{s_U}{U} = 0,007 \ 4$$

- Standard deviation of the velocity at the centre during calibration, as above we will make:

$$\frac{s_{v_0}}{V_0} = 0,007$$

The standard deviation on the flowrate measurement is therefore:

$$\frac{s_{q_V}}{q_V} = \sqrt{7^2 + 4^2 + 7,4^2 + 7^2} \times 10^{-3} = 0,013$$

and the flowrate is therefore determined with an uncertainty, at a confidence level of 95 %, of:

$$E_{q_V} = \pm 2 \frac{s_{q_V}}{q_V} = \pm 2,6 \%$$

C.2 Calibration by measurement of the local velocity at the point of mean axial velocity

— Standard deviation of the mean axial velocity during calibration: for a measurement made in accordance with this International Standard, we will take for an example as in Annex B:

$$\frac{s_U}{U} = \sqrt{7^2 + (0,64 \times 6,7)^2 + (0,64 \times 10)^2} \times 10^{-3} = 0,010$$

The standard deviation of the other component uncertainties are the same as those mentioned in clause C.1.

The standard deviation on the flowrate measurement is therefore:

$$\frac{s_{q_V}}{q_V} = \sqrt{7^2 + 4^2 + 10^2 + 7^2} \times 10^{-3} = 0,014 6$$

and the flowrate will therefore be determined with an uncertainty, at a confidence level of 95 % of

$$E_{q_V} = \pm 2 \frac{s_{q_V}}{q_V} = \pm 2,9 \%$$

The values obtained in both examples given above serve to illustrate that the uncertainty on a flow measurement made in accordance with this International Standard, with the primary device placed on the axis of the conduit, normally remains less than $\pm 3 \%$.

Publications referred to

See national foreword.

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.
Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.
Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.
Tel: 020 8996 7002. Fax: 020 8996 7001.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager.
Tel: 020 8996 7070.