

---

---

**Fire extinguishing media — Foam  
concentrates —**

Part 2:

**Specification for medium- and high-  
expansion foam concentrates for top  
application to water-immiscible liquids**

*Agents extincteurs — Émulseurs —*

*Partie 2: Spécifications pour les émulseurs moyen et haut  
foisonnements destinés à une application par le haut sur les liquides  
non miscibles à l'eau*



Reference number  
ISO 7203-2:2011(E)

© ISO 2011

..



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2011

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.org](mailto:copyright@iso.org)  
Web [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

Page

Foreword .....	v
Introduction.....	vi
<b>1 Scope .....</b>	<b>1</b>
<b>2 Normative references .....</b>	<b>1</b>
<b>3 Terms and definitions .....</b>	<b>2</b>
<b>4 Classification and uses of foam concentrates .....</b>	<b>3</b>
<b>4.1 Classification .....</b>	<b>3</b>
<b>4.2 Use with sea water .....</b>	<b>3</b>
<b>5 Tolerance of the foam concentrate to freezing and thawing .....</b>	<b>3</b>
<b>6 Sediment in the foam concentrate.....</b>	<b>4</b>
<b>6.1 Sediment before ageing.....</b>	<b>4</b>
<b>6.2 Sediment after ageing.....</b>	<b>4</b>
<b>7 Determination of viscosity for pseudo-plastic foam concentrates .....</b>	<b>4</b>
<b>7.1 Newtonian foam concentrates .....</b>	<b>4</b>
<b>7.2 Pseudo-plastic foam concentrates .....</b>	<b>4</b>
<b>8 pH of the foam concentrate .....</b>	<b>4</b>
<b>8.1 pH limits.....</b>	<b>4</b>
<b>8.2 Sensitivity to temperature .....</b>	<b>4</b>
<b>9 Surface tension of the foam solution .....</b>	<b>4</b>
<b>9.1 Before temperature conditioning.....</b>	<b>4</b>
<b>9.2 Temperature sensitivity .....</b>	<b>4</b>
<b>10 Interfacial tension between the foam solution and cyclohexane .....</b>	<b>5</b>
<b>10.1 Before temperature conditioning.....</b>	<b>5</b>
<b>10.2 Temperature sensitivity .....</b>	<b>5</b>
<b>11 Spreading coefficient of the foam solution on cyclohexane .....</b>	<b>5</b>
<b>12 Expansion and drainage of foam.....</b>	<b>5</b>
<b>12.1 Medium-expansion foam concentrates — Limits .....</b>	<b>5</b>
<b>12.2 High-expansion foam concentrate — Limits .....</b>	<b>5</b>
<b>13 Test fire performance.....</b>	<b>5</b>
<b>14 Marking, packaging and specification sheet.....</b>	<b>6</b>
<b>14.1 Marking.....</b>	<b>6</b>
<b>14.2 Packaging.....</b>	<b>6</b>
<b>14.3 Specification sheet.....</b>	<b>6</b>
<b>Annex A (normative) Preliminary sampling and conditioning of the foam concentrate .....</b>	<b>7</b>
<b>Annex B (normative) Determination of tolerance to freezing and thawing .....</b>	<b>8</b>
<b>Annex C (normative) Determination of volume percentage of sediment.....</b>	<b>10</b>
<b>Annex D (normative) Determination of viscosity for pseudo-plastic foam concentrates .....</b>	<b>11</b>
<b>Annex E (normative) Determination of surface tension, interfacial tension and spreading coefficient.....</b>	<b>13</b>
<b>Annex F (normative) Determination of expansion and drainage time for medium-expansion foam concentrates .....</b>	<b>14</b>

<b>Annex G (normative) Determination of expansion and drainage time for high-expansion foam concentrates.....</b>	<b>19</b>
<b>Annex H (normative) Determination of test fire performance for medium-expansion foam concentrates.....</b>	<b>25</b>
<b>Annex I (normative) Determination of test fire performance for high-expansion foam concentrates .....</b>	<b>29</b>
<b>Annex J (normative) Determination of radiation measurement method .....</b>	<b>33</b>
<b>Annex K (informative) Compatibility .....</b>	<b>37</b>
<b>Bibliography .....</b>	<b>38</b>

.....

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7203-2 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 6, *Foam and powder media and fixed firefighting systems using foam and powder*.

This second edition cancels and replaces the first edition (ISO 7203-2:1995), which has been technically revised.

ISO 7203 consists of the following parts, under the general title *Fire extinguishing media — Foam concentrates*:

- *Part 1: Specification for low-expansion foam concentrates for top application to water-immiscible liquids*
- *Part 2: Specification for medium- and high-expansion foam concentrates for top application to water-immiscible liquids*
- *Part 3: Specification for low-expansion foam concentrates for top application to water-miscible liquids*

## Introduction

Firefighting foams are widely used to control and extinguish fires of flammable liquids and for inhibiting re-ignition. They can also be used to prevent ignition of flammable liquids and, in certain conditions, extinguish fires of solid combustibles.

Foams can be used in combination with other extinguishing media, particularly halons, carbon dioxide and powders, which are the subject of other International Standards including ISO 5923, ISO 6183, ISO 7201-1, ISO 7201-2 and ISO 7202. A specification for foam systems (ISO 7076), which is cited in this part of ISO 7203, is under preparation.

Attention is drawn to Annex K, which deals with the compatibility of foam concentrates, and the compatibility of foams and powders.

# Fire extinguishing media — Foam concentrates —

## Part 2:

# Specification for medium- and high-expansion foam concentrates for top application to water-immiscible liquids

## 1 Scope

This part of ISO 7203 specifies the essential properties and performance of liquid foam concentrates used to make medium- or high-expansion foams or both for the control, extinction and inhibition of reignition of fires of water-immiscible liquids. Minimum performance on certain test fires is specified.

These foams are suitable for top application to fires of water-immiscible liquid. Those foams that comply with ISO 7203-1 are also suitable for top application to fires of water-immiscible liquids.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 304, *Surface active agents — Determination of surface tension by drawing up liquid films*

ISO 3104, *Petroleum products — Transparent and opaque liquids — Determination of kinematic viscosity and calculation of dynamic viscosity*

ISO 3219, *Plastics — Polymers/resins in the liquid state or as emulsions or dispersions — Determination of viscosity using a rotational viscometer with defined shear rate*

ISO 3310-1, *Test sieves — Technical requirements and testing — Part 1: Test sieves of metal wire cloth*

ISO 3696:1987, *Water for analytical laboratory use — Specification and test methods*

ISO 3734, *Petroleum products — Determination of water and sediment in residual fuel oils — Centrifuge method*

ISO 7203-1, *Fire extinguishing media — Foam concentrates — Part 1: Specifications for low-expansion foam concentrates for top application to water-immiscible liquids*

BS 5117-1.3:1985, *Testing corrosion inhibiting, engine coolant concentrate (“antifreeze”). Methods of test for determination of physical and chemical properties. Determination of freezing point*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

- 3.1**  
**characteristic value**  
value declared by the foam concentrate supplier for the chemical and physical properties and the performances of the foam, foam solution, and foam concentrate
- 3.2**  
**25 % drainage time**  
time for 25 % of the liquid content of a foam to drain out
- 3.3**  
**50 % drainage time**  
time for 50 % of the liquid content of a foam to drain out
- 3.4**  
**expansion**  
ratio of the volume of foam to the volume of the foam solution from which it was made
- 3.5**  
**low-expansion**  
with expansion in the range 1 to 20, as applied to foam and to associated equipment, systems and concentrates
- 3.6**  
**medium-expansion**  
with expansion in the range 21 to 200, as applied to foam and to associated equipment, systems and concentrates
- 3.7**  
**high-expansion**  
with expansion greater than or equal to 200, as applied to foam and to associated equipment, systems and concentrates
- 3.8**  
**foam**  
(firefighting) aggregate of air-filled bubbles formed from an aqueous solution of a suitable foam concentrate
- 3.9**  
**foam concentrate**  
**concentrate**  
liquid which, when mixed with water in the appropriate concentration, gives a foam solution
- 3.10**  
**protein foam concentration**  
**P**  
foam concentrate derived from hydrolysed protein materials
- 3.11**  
**fluoroprotein foam concentrate**  
**FP**  
protein foam concentrate with added fluorinated surface-active agents
- 3.12**  
**synthetic foam concentrate**  
**S**  
foam concentrate based on a mixture of hydrocarbon surface-active agents and which can contain fluorocarbons with additional stabilizers



**3.13****alcohol-resistant foam concentrate****AR**

foam concentrate resistant to breakdown when applied to the surface of alcohol or other water-miscible solvents

**3.14****aqueous film-forming foam concentrate****AFFF**

foam concentrate based on a mixture of hydrocarbon and fluorinated surface-active agents with the ability to form an aqueous film on the surface of some hydrocarbons

**3.15****film-forming fluoroprotein foam concentrate****FFFP**

fluoroprotein foam concentrate that has the ability to form an aqueous film on the surface of some hydrocarbons

**3.16****foam solution**

solution of foam concentrate and water

**3.17****forceful application**

application of foam such that it falls directly onto the surface of a liquid fuel

**3.18****gentle application**

application of foam indirectly to the surface of a liquid fuel via a backboard, tank wall or other surface

**3.19****sediment**

insoluble particles in the foam concentrate

**3.20****spreading coefficient**

value calculated from the measured surface and interfacial tensions to indicate the ability of one liquid to spontaneously spread across the surface of another

**4 Classification and uses of foam concentrates****4.1 Classification**

The foam concentrate shall be classified as medium- or high-expansion or both and shall comply with the appropriate requirements.

**4.2 Use with sea water**

If a foam concentrate is marked as suitable for use with sea water, the recommended concentrations for use with fresh water and sea water shall be identical.

**5 Tolerance of the foam concentrate to freezing and thawing**

Before and after temperature conditioning in accordance with A.2, the foam concentrate, if claimed by the supplier not to be adversely affected by freezing and thawing, shall show no visual sign of stratification and non-homogeneity, when tested in accordance with Annex B.

Foam concentrates complying with this clause shall be tested for compliance with the appropriate requirements given in other clauses of this part of ISO 7203 after freezing and thawing in accordance with A.2.1.

## 6 Sediment in the foam concentrate

### 6.1 Sediment before ageing

Any sediment in the concentrate prepared in accordance with A.1 shall be dispersible through a 180 µm sieve, and the volume percentage of sediment shall be not more than 0,25 % when tested in accordance with Annex C.

### 6.2 Sediment after ageing

Any sediment in the concentrate aged in accordance with C.1 shall be dispersible through a 180 µm sieve, and the volume percentage of sediment shall be not more than 1,0 % when tested in accordance with Annex C.

## 7 Determination of viscosity for pseudo-plastic foam concentrates

### 7.1 Newtonian foam concentrates

The viscosity of the foam concentrate at the lowest temperature for use claimed by the manufacturer shall be determined in accordance with ISO 3104. If the viscosity is greater than 200 mm/s, the container shall be marked "This concentrate can require special proportioning equipment".

### 7.2 Pseudo-plastic foam concentrates

The viscosity of the foam concentrate shall be determined in accordance with Annex D. If the viscosity at the lowest temperature for use is greater than or equal to 120 mPa/s at 375/s, the container shall be marked "Pseudo-plastic foam concentrate. This concentrate can require special proportioning equipment".

## 8 pH of the foam concentrate

### 8.1 pH limits

The pH of the foam concentrate, before and after temperature conditioning in accordance with A.2, shall be not less than 6,0 and not more than 8,5 at  $(20 \pm 2)$  °C.

### 8.2 Sensitivity to temperature

The difference in pH between before and after temperature conditioning shall not be greater than 1,0 pH units.

## 9 Surface tension of the foam solution

### 9.1 Before temperature conditioning

The surface tension of the foam solution prepared from the concentrate, before temperature conditioning in accordance with A.2, at the supplier's recommended concentration, shall be within  $\pm 10$  % of the characteristic value when determined in accordance with E.2.

### 9.2 Temperature sensitivity

The surface tension of the foam solution prepared from the concentrate, after temperature conditioning in accordance with A.2, at the supplier's recommended concentration, shall be determined in accordance with E.2.

The value obtained after temperature conditioning shall not be less than 0,95 times, or more than 1,05 times, the value obtained before temperature conditioning.

## 10 Interfacial tension between the foam solution and cyclohexane

### 10.1 Before temperature conditioning

Before temperature conditioning in accordance with A.2, the difference between the interfacial tension between the foam solution prepared from the foam concentrate and cyclohexane (when determined in accordance with E.3) and the characteristic value for interfacial tension shall not exceed 1,0 mN/m or 10 % of the characteristic value, whichever is the greater.

### 10.2 Temperature sensitivity

After temperature conditioning in accordance with A.2, the interfacial tension between the foam solution prepared from the foam concentrate and cyclohexane shall be determined in accordance with E.3.

The two values obtained before and after temperature conditioning shall not differ by more than 0,5 mN/m.

## 11 Spreading coefficient of the foam solution on cyclohexane

Before and after temperature conditioning in accordance with A.2, the spreading coefficient of the foam solution prepared from a concentrate claimed by the supplier to be “film-forming” shall be positive when calculated in accordance with E.4.

NOTE Foam concentrates complying with this clause are more likely to be of type AFFF or FFFP than of type FP, P or S.

## 12 Expansion and drainage of foam

### 12.1 Medium-expansion foam concentrates — Limits

The foam produced from the foam concentrate, before and after temperature conditioning in accordance with A.2, with potable water and, if appropriate, with the synthetic sea water of H.2.4, shall have an expansion of not less than 50 when tested in accordance with Annex F.

### 12.2 High-expansion foam concentrate — Limits

The foam produced from the foam concentrate, before and after temperature conditioning in accordance with A.2, with potable water and, if appropriate, with the synthetic sea water of I.2.4, shall have an expansion of not less than 201 when tested in accordance with Annex G.

## 13 Test fire performance

The foam produced from the foam concentrate with potable water, and if appropriate, with the synthetic sea water of H.2.4 and/or I.2.4, shall have an extinguishing performance class and burn-back resistance level as specified in Table 1 when tested in accordance with Annex H or Annex I, or both, as appropriate.

Table 1 — Test fire performance

Types of expansion foam	Medium-expansion foam	High-expansion foam
Extinction time, seconds	Not more than 120	Not more than 150
1 % burn-back time, seconds	Not less than 30	Not applicable

## 14 Marking, packaging and specification sheet

### 14.1 Marking

14.1.1 The following information shall be marked on the shipping container:

- a) designation (identifying name) of the concentrate and, as appropriate, the words “medium” or “high”, or “medium and high” and “expansion foam concentrate”;
- b) if the concentrate complies with Clause 11, the words “aqueous film-forming”;
- c) recommended concentration for use (most commonly 1 %, 3 % or 6 %);
- d) any tendency of the foam concentrate to cause harmful physical effects, the methods required to avoid them and the first aid treatment if they should occur;
- e) recommended storage temperature and temperature of use;
- f) if the concentrate complies with Clause 5, the words “Not affected by freezing and thawing” or, if the foam concentrate does not comply with Clause 5, the words “Do not freeze”;
- g) nominal quantity in the container;
- h) supplier's name and address;
- i) batch number;
- j) words “Not suitable for use with sea water” or “Suitable for use with sea water”, as appropriate.

**WARNING — It is extremely important that the foam concentrate, after dilution with water to the recommended concentration, shall not, in normal usage, present a significant toxic hazard to life in relation to the environment.**

14.1.2 Markings on shipping containers shall be permanent and legible.

14.1.3 It is recommended that non-Newtonian concentrates be appropriately identified.

14.1.4 Foam concentrates complying with ISO 7203-1 shall also be marked “low-expansion”.

### 14.2 Packaging

The packaging of the foam concentrate shall ensure that the essential characteristics of the concentrate are preserved when stored and handled in accordance with the supplier's recommendations.

### 14.3 Specification sheet

14.3.1 If the foam concentrate is Newtonian and the viscosity at the lowest temperature for use is more than 200 mm<sup>2</sup>/s when measured in accordance with ISO 3104, the words “This concentrate can require special proportioning equipment” shall be included on the specification sheet.

14.3.2 If the foam concentrate is pseudo-plastic and the viscosity at the lowest temperature for use is greater than or equal to 120 mPa/s at 375/s, the words “Pseudo-plastic foam concentrate. This concentrate can require special proportioning equipment” shall be included on the specification sheet.

14.3.3 It is recommended that non-Newtonian concentrates be appropriately identified.

## Annex A (normative)

### Preliminary sampling and conditioning of the foam concentrate

#### A.1 Preliminary sampling

The sampling method shall ensure representative samples, whether taken from a bulk container or a number of individual packages.

Store samples in fully closed containers.

NOTE Containers with a capacity of 20 l are suitable.

#### A.2 Conditioning of foam concentrate

**A.2.1** If the supplier claims that the concentrate is not adversely affected by freezing and thawing, condition the concentrate sample through four cycles of freezing and thawing, generally as described in B.2, before conditioning in accordance with A.2.2. If the foam concentrate is adversely affected by freezing and thawing, it shall be conditioned according to A.2.2 without prior freezing and thawing.

**A.2.2** Condition the concentrate in the sealed container for 7 d at  $(60 \pm 2) ^\circ\text{C}$ , followed by 1 d at  $(20 \pm 5) ^\circ\text{C}$ .

#### A.3 Subsequent testing

Test samples prepared in accordance with A.1, or A.1 and A.2 as appropriate. Agitate the sample container before sampling for further tests.

## Annex B (normative)

### Determination of tolerance to freezing and thawing

#### B.1 Apparatus

The usual laboratory apparatus and, in particular, the following.

**B.1.1 Freezing chamber**, capable of achieving the temperatures required in B.2.

**B.1.2 Polyethylene tube**, approximately 10 mm in diameter, approximately 400 mm long and sealed and weighted at one end, with suitable spacers attached.

Figure B.1 shows a typical form.

**B.1.3 Measuring cylinder**, glass, of 500 ml capacity, approximately 400 mm high and approximately 65 mm in diameter, with a stopper.

#### B.2 Procedure

Set the temperature of the freezing chamber (B.1.1) to at least 10 °C below the freezing point of the sample, measured in accordance with BS 5117-1.3, excluding 5.2.


To prevent the glass measuring cylinder (B.1.3) from breaking due to expansion of the foam concentrate on freezing, insert the tube (B.1.2) into the measuring cylinder with the sealed end downward, weighted if necessary to avoid flotation, the spacers ensuring it remains approximately on the central axis of the cylinder. Fill the cylinder and fit the stopper.

Place the cylinder in the freezing chamber, cool it and maintain at the required temperature for 24 h. At the end of this period, thaw the sample for not less than 24 h and not more than 96 h in an ambient temperature of  $(20 \pm 5)$  °C.

Repeat three times to give four cycles of freezing and thawing before testing.

Examine the sample for stratification and non-homogeneity.

Nominal dimensions in millimetres



**Key**

- 1 spacers (e.g. plastic cable strap)
- 2 weight at sealed end

**Figure B.1 — Typical form of polyethylene tube**

## Annex C (normative)

### Determination of volume percentage of sediment

#### C.1 Sampling

Use a sample prepared in accordance with A.1. Ensure that any sediment is dispersed by agitating the sample container. Take two samples, testing one immediately and the other after ageing for  $(24 \pm 2)$  h at  $(60 \pm 2)$  °C in a filled container without access to air.

#### C.2 Apparatus

The usual laboratory apparatus and, in particular, the following.

##### C.2.1 Centrifuge tubes, graduated.

Centrifuge tubes complying with ISO 3734 are suitable.

##### C.2.2 Centrifuge, operating at $(6\ 000 \pm 600)$ m/s<sup>2</sup>.

A centrifuge complying with ISO 3734 is suitable.

##### C.2.3 Sieve, of nominal aperture size 180 µm, complying with ISO 3310-1.

##### C.2.4 Wash bottle, plastic.

#### C.3 Procedure

Centrifuge each sample of the concentrate for  $(10 \pm 1)$  min. Determine the volume of the sediment and record it as a percentage of volume of the centrifuged sample volume.

Wash the contents of the centrifuge tube (C.2.1) onto the sieve (C.2.3) and check whether the sediment can or cannot be dispersed through the sieve by the jet from the plastic wash bottle (C.2.4).



## Annex D (normative)

### Determination of viscosity for pseudo-plastic foam concentrates

#### D.1 General

This annex gives the procedure for determining the viscosity for pseudo-plastic foam concentrates. The procedure is described in ISO 3219.

NOTE Pseudo-plastic foam concentrates are a particular class of non-Newtonian foam concentrate and have a viscosity which decreases with increasing shear rate at constant temperature.

#### D.2 Viscosity determination

##### D.2.1 Apparatus

The usual laboratory apparatus and a rotational viscometer in accordance with ISO 3219 with the following parameters:

- maximum shear stress of  $\geq 75$  Pa;
- maximum shear rate of  $\geq 600$ /s.

The viscometer shall be fitted with a temperature control unit which can maintain the sample temperature within  $\pm 1$  °C of the required temperature.

##### D.2.2 Test temperatures

The viscosity of the foam concentrate shall be measured from 20 °C down to, and including, the lowest temperature for use claimed by the manufacturer, in increments of 10 °C. Use a fresh sample for each temperature.

##### D.2.3 Viscosity measurement

If the sample contains suspended air bubbles, the sample shall be centrifuged for 10 min using the apparatus specified in C.2.1 and C.2.2 before the sample is placed in the apparatus.

The test should be performed according to the following test procedure:

- a) Adjust the temperature control unit.
- b) Set the gap.
- c) Apply the sample.
- d) Wait a minimum of 10 min (with no shear) to reach temperature equilibrium.
- e) Pre-shear for 1 min at 600/s.
- f) Wait 1 min without shearing.
- g) Measure the shear stress for 10 s at each shear rate, starting at the lowest shear rate (preferably at 75/s).

Measure the shear stress at a minimum of eight different shear rates over the range (0/s to 600/s), e.g. 75/s, 150/s, 225/s, 300/s, 375/s, 450/s, 525/s, 600/s. Calculate the apparent viscosity,  $\nu$ , expressed in millipascal-seconds, as given in Equation (D.1)

$$\nu = 1000 \times \frac{s_1}{s_2} \quad (\text{D.1})$$

where

$s_1$  is the shear stress, expressed in pascals;

$s_2$  is the shear rate, expressed in reciprocal seconds.

#### **D.2.4 Results**

Report the results as a table including test temperature, expressed in degrees Celsius, the shear rate, expressed in reciprocal seconds, the shear stress, expressed in reciprocal seconds, and the apparent viscosity, expressed in millipascal-seconds.

## Annex E (normative)

### Determination of surface tension, interfacial tension and spreading coefficient

#### E.1 Reagents and materials

**E.1.1 Solution of foam concentrate**, at the recommended concentration for use in freshly made analytical water complying with grade 3 of ISO 3696:1987 and with surface tension not less than 70 mN/m.

NOTE The solution can be made up in a 100 ml volumetric flask, using a pipette to measure the foam concentrate.

**E.1.2 Cyclohexane**, of purity not less than 99 %, for interfacial tension and spreading coefficient only.

#### E.2 Procedure for surface tension

Determine the surface tension of the solution (E.1.1) at a temperature of  $(20 \pm 1) ^\circ\text{C}$ , using the ring method in accordance with ISO 304.

#### E.3 Procedure for interfacial tension

After measuring the surface tension in accordance with E.2, introduce a layer of cyclohexane (E.1.2) at  $(20 \pm 1) ^\circ\text{C}$  onto the foam solution (E.1.1), being careful to avoid contact between the ring and the cyclohexane. Wait  $(6 \pm 1)$  min and then measure the interfacial tension.

#### E.4 Spreading coefficient

Calculate the spreading coefficient,  $S$ , expressed in millinewtons per metre, between the solution (E.1.1) and cyclohexane (E.1.2) from Equation (E.1):

$$S = Y_c - Y_f - Y_i \quad (\text{E.1})$$

where

$Y_c$  is the surface tension of the cyclohexane, expressed in millinewtons per metre;

$Y_f$  is the surface tension of the foam solution, expressed in millinewtons per metre;

$Y_i$  is the interfacial tension between the foam solution and cyclohexane, expressed in millinewtons per metre.

## Annex F (normative)

### Determination of expansion and drainage time for medium-expansion foam concentrates

#### F.1 Apparatus

The usual laboratory apparatus and, in particular, the following.

**F.1.1 Collecting vessel**, plastic, cylindrical, of volume known to  $\pm 1$  %, equipped with a bottom discharge facility, as shown in Figure F.1.

**F.1.2 Foam-making equipment**, with nozzle as shown in Figures F.2 and F.3 that, when tested with water, has a flow rate of between 3,1 l/min and 3,4 l/min at a nozzle pressure of  $(500 \pm 10)$  kPa [ $(5,0 \pm 0,1)$  bar].

**F.1.3 Stop watch**, or other timing device.

#### F.2 Temperature conditions

Carry out the tests under the following temperature conditions:

- air temperature  $(20 \pm 5)$  °C;
- foam solution temperature  $(17,5 \pm 2,5)$  °C.

#### F.3 Procedure

**F.3.1** Prepare two samples of foam concentrate in accordance with Annex A. Condition one in accordance with Annex A.

**F.3.2** Carry out the remainder of the procedure for each sample on the same day. Prepare a foam solution of each sample following the supplier's recommendations for concentration, maximum premix time, compatibility with the test equipment, avoiding contamination by other types of foam, etc. Use potable water to make up the foam solutions and, if the supplier claims that the concentrate is suitable for sea water, also make foam solutions at the same concentration using the simulated sea water prepared in accordance with F.4. The concentration used in simulated sea water shall be the same as the concentration used in potable water.

**F.3.3** Wet the vessel internally and weigh it. Record the mass as  $m_1$ . Set up the foam equipment and adjust the nozzle pressure to within the range  $(500 \pm 10)$  kPa [ $(5,0 \pm 0,1)$  bar] to give a flow rate between 3,1 l/min and 3,4 l/min. With discharge facility closed, collect foam, taking care that voids are not formed in the vessel, and start the timing device when the vessel is half full. As soon as the vessel is full, stop collecting foam and strike the foam surface level with the rim, and clean the exterior surface of the vessel of foam. Weigh the vessel and record the mass as  $m_2$ .

Calculate the expansion,  $E$ , from Equation (F.1):

$$E = \frac{V}{m_2 - m_1} \quad (\text{F.1})$$

where

$V$  is the vessel volume, expressed in litres;

$m_1$  is the mass, expressed in kilograms, of the empty vessel;

$m_2$  is the mass, expressed in kilograms, of the full vessel.

Assume that the density of the foam solution is 1,0 kg/l.

Open the drainage facility and measure the 25 % and 50 % drainage time. Determine the drainage either by placing the vessel on a set of scales and recording the mass loss or by collecting the drained foam solution in a measuring cylinder. Adjust the drainage facility such that the drained foam solution can flow out but the passage of foam is prevented. For each sample carry out the test three times.

**F.3.4** For each sample, calculate the mean values of the three tests for the expansion and 25 % and 50 % drainage time.


#### F.4 Simulated sea water

Prepare the simulated sea water by dissolving the components as given in Table F.1.

**Table F.1 — Components of simulated sea water**

Percent mass fraction	Component	Chemical formula
2,50	Sodium chloride	NaCl
1,10	Magnesium chloride	MgCl <sub>2</sub> ·6H <sub>2</sub> O
0,16	Calcium chloride	CaCl <sub>2</sub> ·2H <sub>2</sub> O
0,40	Sodium sulfate	Na <sub>2</sub> SO <sub>4</sub>
95,84	Potable water	—

Dimensions in millimetres



**Key**


1 bottom discharge facility

NOTE 1 All dimensions are nominal.

NOTE 2 Nominal volume is 200 l.

**Figure F.1 — Collecting vessel for determination of expansion and drainage time**

Dimensions in millimetres

**Key**

	Number	Size
1 ring	1	
2 net	1	
3 pipe	1	
4 nut	1	M6M 6
5 acorn nut	3	MHM 6
6 nipple	1	G-1/4"-1/8"
7 tee	1	G-1/4"
8 nipple	1	G-1/4"
9 valve	1	G-1/4"
10 nipple	1	G-1/4"-3/8"
11 nozzle	1	G-1/8" GG3,5
12 collar	1	
13 pressure gauge	1	G-1/4" 1-1,6 MPa D = 40


a The nozzle shall be coaxial with the barrel of the foam branch.

b The pressure gauge shall be positioned so as not to interfere with the air inlet of the branch.

**Figure F.2 — Medium-expansion foam-making nozzle<sup>1)</sup>**

1) An example of suitable apparatus, available commercially, is supplied by Svenska Skum AB, PO Box 674, S442, 18 Kungälv, Sweden. This information is given for the convenience of users of this part of ISO 7203 and does not constitute an endorsement by ISO of this product.

Dimensions in millimetres



- a The screen shall be 24 mesh per inch, with a wire diameter of 0,4 mm.

**Figure F.3 — Net (2)**



## Annex G (normative)

### Determination of expansion and drainage time for high-expansion foam concentrates

#### G.1 Apparatus

The usual laboratory apparatus and, in particular, the following.

**G.1.1 Collecting vessel** (see Figure G.1), of volume,  $V$ , of approximately 500 l and that is accurately known to  $\pm 5$  l, equipped with a drain at the base.

**G.1.2 High-expansion foam generator**, with nozzle as shown in Figures G.2, G.3 and G.4 that, when tested with water, has a flow rate of between 6,0 l/min and 6,2 l/min at a nozzle pressure of  $(500 \pm 10)$  kPa [ $(5,0 \pm 0,1)$  bar].

**G.1.3 Stop watch**, or other timing device.

#### G.2 Temperature conditions

Carry out the tests under the following temperature conditions:

- air temperature  $(20 \pm 5)$  °C;
- foam solution temperature  $(17,5 \pm 2,5)$  °C.

#### G.3 Procedure


**G.3.1** Prepare two samples of foam concentrate in accordance with Annex A. Condition one in accordance with Annex A.

**G.3.2** Carry out the remainder of the procedure for each sample on the same day. Prepare a foam solution of each sample following the supplier's recommendations for concentration, maximum premix time, compatibility with the test equipment, avoiding contamination by other types of foam, etc. Use potable water to make up the foam solutions and, if the supplier claims that the concentrate is suitable for sea water, also make foam solutions at the same concentration using the simulated sea water prepared in accordance with G.4. The concentration used in simulated sea water shall be the same as the concentration used in potable water.

**G.3.3** Wet the vessel internally and weigh it. Record the mass as  $m_1$ . Set up the foam equipment and adjust the nozzle pressure within the range  $(500 \pm 10)$  kPa [ $(5,0 \pm 0,1)$  bar] to give a flow rate of between 6,0 l/min and 6,2 l/min. With the drain at the base closed, collect foam, taking care that voids are not formed in the vessel. Start the timing device when the vessel is half full. As soon as the vessel is full, stop collecting foam, strike the foam surface level with the rim, and clean the exterior surface of the vessel of foam. Weigh the vessel and record the mass as  $m_2$ .



Dimensions in millimetres



**Key**


1 bottom discharge facility

NOTE 1 All dimensions are nominal.

NOTE 2 Nominal volume is 200 l.

**Figure G.1 — Collecting vessel for determination of expansion and drainage time**

Dimensions in millimetres




**Key**

	Number	Dimension	Material
1 housing	1		
2 ring	1		
3 perforated plate	1	1 mm	SS 1312
4 motor (1 400 rpm; 0,3 HP; 50 Hz; 3 ph; 380 VAC)	1	Ø405 mm, Ø10 × 12	
5 fan (1 400 rpm; 7,5 mm water, 2 000 m <sup>3</sup> /h)	1		
6 screw	8	M6S 6 × 16	SS 2343
7 nut	8	M6M 6	SS 2343
8 washer	8	RB 6,4	SS 2343
9 support	2		
10 screw	20	M6S 6 × 14	SS 2343
11 washer	20	RB 8,4	SS 2343
12 nut	6	M6M 8	SS 2343
13 nut	4	MVM-K 6	SS 2343
14 screen	1		
15 valve	1	OLO R ¼"	
16 pressure gauge	1	Ø63R¼", 0-10 bar	galvanized
17 tee	1		galvanized
18 nipple	2		
19 pipe	1		
20 bend	1		galvanized
21 nozzle	1	¼"HH 6,5	
22 inspection cover	1		
23 screw	1	M6S 5 × 16	SS 2343
24 washer	1	Ø18/5,5 × 2	SS 2343
25 handle	1		

**Figure G.2 — High-expansion foam generator<sup>2)</sup> — General arrangement**

2) An example of suitable apparatus, available commercially, is supplied by Svenska Skum AB, PO Box 674, S 442, 18 Kungälv, Sweden. This information is given for the convenience of the users of this part of ISO 7203 and does not constitute an endorsement by ISO of this product.


Dimensions in millimetres



**Key**

- 1 housing (2 mm plate)
- 2 ring
- 26 collar
- 27 and 28 screen supports (2 mm plate)
- 29 bar reinforcement
- 30 legs
- 31 screw
- 32 nut

**Figure G.3 — High-expansion foam generator — Housing (1)**



**Key**

- 33 support ring (1,5 mm plate)
- 34 perforated screen (0,7 mm plate, 2 mm holes at 3 mm pitch)

**Figure G.4 — High-expansion foam generator — Screen (14)**

## Annex H (normative)

### Determination of test fire performance for medium-expansion foam concentrates

#### H.1 General

This annex specifies the procedure for determining the test fire performance for medium-expansion foam concentrates. The tests described in this annex are more expensive and time-consuming than the other tests described in this part of ISO 7203. It is recommended that they be carried out at the end of the test programme, so as to avoid the expense of unnecessary testing.

Testing at temperatures above the range required by this part of ISO 7203 may result in poor performance, and will not result in conformity to this part of ISO 7203.

#### H.2 General conditions

##### H.2.1 Test series and criteria for success

###### H.2.1.1 Foam concentrates not compatible with sea water

Carry out two or three tests (the third test is not necessary if the first two are both successful or if neither are successful). The concentrate conforms to Clause 13 if two tests are successful.

###### H.2.1.2 Foam concentrates compatible with sea water

Carry out one of the first two tests with potable water and the other with the simulated sea water of the composition given in F.4. If both are successful, repeat the test with the greater of the two extinction times. If the extinction times are identical, repeat the sea water test. If the repeat test is successful, terminate the test series. If the repeat test is unsuccessful, carry out a second repeat test.

If one of the first tests is not successful, repeat the test. If this repeat test is successful, carry out a second repeat test; otherwise terminate the test series. The concentrate conforms to Clause 13 if three tests are successful.

##### H.2.2 Temperature and wind speed

Carry out the tests under the following conditions:

- air temperature (15 ± 5) °C;
- fuel temperature (17,5 ± 2,5) °C;
- water temperature (17,5 ± 2,5) °C;
- foam solution temperature (17,5 ± 2,5) °C;
- maximum wind speed in the proximity of the fire tray 3 m/s.

NOTE If necessary, some form of wind-screen can be used.

### H.2.3 Records

During the fire test, record the following:

- a) location;
- b) air temperature;
- c) fuel temperature;
- d) water temperature;
- e) foam solution temperature;
- f) wind speed;
- g) 90 % control time;
- h) 99 % control time;
- i) extinction time;
- j) 1 % burn-back time.

It is recommended that the time is recorded at 1 % burn-back. Control times and burn-back time can be determined either visually by an experienced person or from thermal radiation measurements. Annex J gives details of a method suitable for medium-expansion foams.

### H.2.4 Foam solution

Prepare a foam solution following the recommendations from the supplier for concentration, maximum premix time, compatibility with the test equipment, avoiding contamination by other types of foam, etc.

Use potable water to prepare the foam solution and, if the supplier claims that the concentrate is suitable for use in sea water, make a second foam solution at the same concentration using simulated sea water in accordance with F.4.

### H.2.5 Fuel

Use an aliphatic hydrocarbon mixture having physical properties according to the following specification:

- a) distillation range: 84 °C to 105 °C;
- b) maximum difference between initial and final boiling points: 10 °C;
- c) maximum aromatic content: 1 % mass fraction;
- d) density at 15 °C: (700 ± 20) kg/m<sup>3</sup>.

NOTE 1 The normal value of surface tension of the aliphatic hydrocarbon mixture measured in accordance with H.2.1 is 21 mN/m to 22 mN/m.

NOTE 2 Typical fuels meeting this specification are certain solvent fractions sometimes referred to as commercial heptane.



## H.3 Fire test

### H.3.1 Apparatus

The usual laboratory apparatus and, in particular, the following.

**H.3.1.1 Circular fire tray**, stainless steel grade 314, with dimensions as follows:

- internal diameter at rim (1 480 ± 15) mm;
- depth (150 ± 10) mm;
- nominal thickness of steel wall 2,5 mm.

NOTE The tray has an area of approximately 1,73 m<sup>2</sup>.

**H.3.1.2 Foam-making equipment**, as described in F.1.2.

**H.3.1.3 Burn-back pot**, stainless steel, of nominal thickness 2,5 mm, diameter (150 ± 5) mm and height (150 ± 5) mm, with a bracket so that it can be suspended directly on the rim of the fire tray.

The upper rim of the burn-back pot shall be level with, and in contact with, the upper rim of the fire tray.



### H.3.2 Test procedure

Place the tray directly on the ground and ensure that it is level. Add approximately 30 l of water and (55 ± 2) l of fuel to give a nominal 50 mm fuel depth, with approximately 100 mm between the fuel surface and the upper rim of the tray wall.

Suspend the burn-back pot containing (0,9 ± 0,1) l of fuel on the sheltered side of the fire tray.

Ignite the fuel not less than 3 min and not more than 5 min after adding it. Not less than 45 s after full involvement of the surface of the fuel, mount the medium-expansion nozzle horizontally on the rim of the tray, as shown in Figure H.1. Start foam application (60 ± 2) s after full involvement. Apply foam for (120 ± 2) s. Record the extinction time as the time after the start of foam application at which all flames in the fire tray are extinguished. Following foam application, allow the fire in the burn-back pot to burn until sustained flames appear above the foam blanket. Record this time as the 1 % burn-back time.

If the burn-back pot is extinguished due to overflow of foam during foam application, re-ignite it immediately.



**Key**

- 1 foam-making nozzle
- 2 tray
- 3 burn-back pot, suspended outside tray
- 4 fuel
- 5 water

**Figure H.1 — Test fire arrangement for medium-expansion foam**

## Annex I (normative)

### Determination of test fire performance for high-expansion foam concentrates

#### I.1 General

This annex specifies the procedure for determining the test fire performance for high-expansion foam concentrates. The tests described in this annex are more expensive and time-consuming than the other tests described in this part of ISO 7203. It is recommended that they be carried out at the end of the test programme, so as to avoid the expense of unnecessary testing.

Testing at temperatures above the range required by this part of ISO 7203 may result in poor performance, and will not result in conformity to this part of ISO 7203.

#### I.2 General conditions

##### I.2.1 Test series and criteria for success

###### I.2.1.1 Foam concentrates not compatible with sea water

Carry out two or three tests (the third test is not necessary if the first two are both successful or if neither are successful). The concentrate conforms to Clause 13 if two tests are successful.

###### I.2.1.2 Foam concentrates compatible with sea water

Carry out one of the first two tests with potable water and the other with simulated sea water of the composition given in G.4. If both are successful, repeat the test with the greater of the two extinction times. If the extinction times are identical, repeat the sea water test. If the repeat test is successful, terminate the test series. If the repeat test is unsuccessful, carry out a second repeat test.

If one of the first tests is not successful, repeat that test. If this repeat test is successful, carry out a second repeat test; otherwise terminate the test series. The concentrate conforms to Clause 13 if three tests are successful.

##### I.2.2 Temperature and wind speed

Carry out the tests under the following conditions:

- air temperature (15 ± 5) °C;
- fuel temperature (17,5 ± 2,5) °C;
- water temperature (17,5 ± 2,5) °C;
- foam solution temperature (17,5 ± 2,5) °C;
- maximum wind speed in the proximity of the fire tray 3 m/s.

NOTE If necessary, some form of wind-screen can be used.

### I.2.3 Records

During the fire test, record the following:

- a) location;
- b) air temperature;
- c) fuel temperature;
- d) water temperature;
- e) foam solution temperature;
- f) wind speed;
- g) 90 % control time;
- h) 99 % control time;
- i) extinction time.

NOTE Control times can be determined visually by an experienced person.

### I.2.4 Foam solution

Prepare a foam solution following the recommendations from the supplier for concentration, maximum premix time, compatibility with the test equipment, avoiding contamination by other types of foam, etc.

Use potable water to prepare the foam solution and, if the supplier claims that the concentrate is suitable for use in sea water, make a second foam solution at the same concentration using simulated sea water in accordance with G.4.

### I.2.5 Fuel

Use an aliphatic hydrocarbon mixture having physical properties according to the following specification:

- a) distillation range: 84 °C to 105 °C;
- b) maximum difference between initial and final boiling points: 10 °C;
- c) maximum aromatic content: 1 % mass fraction;
- d) density at 15 °C:  $(700 \pm 20) \text{ kg/m}^3$ .

NOTE 1 The normal value of surface tension of the aliphatic hydrocarbon mixture measured in accordance with I.2.1 is 21 mN/m to 22 mN/m.

NOTE 2 Typical fuels meeting this specification are certain solvent fractions sometimes referred to as commercial heptane.

## I.3 Fire test

### I.3.1 Apparatus

The usual laboratory apparatus and, in particular, the following.

**I.3.1.1 Circular fire tray**, stainless steel grade 314, with dimensions as follows:

- internal diameter at rim (1 480 ± 15) mm;
- depth (150 ± 10) mm;
- nominal thickness of steel wall 2,5 mm.

NOTE The tray has an area of approximately 1,73m<sup>2</sup>.

**I.3.1.2 High-expansion foam generator**, as described in G.1.2, mounted horizontally (650 ± 50) mm above the ground.



**I.3.1.3 Fire screens**, of nominal 5 mm square metal mesh, to form the nominal arrangement shown in Figure I.1.

### I.3.2 Test procedure

Place the tray directly on the ground and ensure that it is level. Add approximately 30 l of water and (55 ± 2) l of fuel to give a nominal 50 mm fuel depth, with approximately 100 mm between the fuel surface and the upper rim of the tray wall.

Place the net screens around the fire tray as shown in Figure I.1. Ignite the fuel not less than 3 min and not more than 5 min after adding it. Not less than 45 s after full involvement of the surface of the fuel, commence foam generation with the foam generator no nearer than 3 m to the tray.

Wait (60 ± 2) s after full involvement, then move the foam generator to the opening in the net screen and apply foam to the fire. Apply foam for (120 ± 2) s. Record the extinction time as the period from the start of foam application to extinction.



**Key**

- 1 foam-making nozzle
- 2 tray
- 3 burn-back pot, suspended outside tray
- 4 fuel
- 5 water

NOTE All dimensions are nominal.

**Figure I.1 — Test fire arrangement for high-expansion foam**

## Annex J (normative)

### Determination of radiation measurement method

#### J.1 Evaluation

Radiation measurement is a convenient and objective way to monitor the performance of a foam during the fire performance test. It reduces the need for visual observations (except for flame flickers and time necessary for complete extinction).


This annex describes the equipment and procedure used in a series of tests in one testing laboratory, and the methods used to interpret and present the results. See Reference [7] for details. The method is suitable for low-and medium-expansion foams, but not for high-expansion foams.

#### J.2 General arrangement of test

Radiometers should be placed diametrically in relation to the tray, as shown in Figure J.1. The distance between the meters and the rim of the tray should be not less than twice the diameter,  $D$ , of the tray; the height above the rim should be not less than 1,5 m.

NOTE The maximum distance is limited by the sensitivity of the radiometers.

Radiation levels should be recorded continuously or with intervals not exceeding 1 s.



#### Key

- 1 radiometer
- 2 circular fire tray

**Figure J.1 — Location of radiometers for recording heat radiation during fire performance tests**

### J.3 Technical data for radiometers

Two radiometers<sup>3)</sup> of type Gordon or Schmidt-Boelter should be used. The meters should be cooled with water. The temperature of the cooling water should be  $(30 \pm 10)$  °C, held constant during the measurements.

The radiometers absorb at least 90 % of the incoming radiation within the range of wavelengths 0,6 µm to 15 µm.

For a fully developed fire, the radiometer reading should be not less than 0,6 times the full scale.

The radiometers should have maximum non-linearity of  $\pm 3$  % of nominal range of measurement, and a maximum response time of 2 s (up to 63 % of full response).

A radiometer with protective glass may be used, provided that the requirements on spectral sensitivity are satisfied. If it is considered necessary, the utilization of the range of measurement specified above may be changed, if the radiometers have a better linearity. Less than 40 % utilization is not advisable, as the influence of background radiation can have too great an effect.

### J.4 Procedure

Correct the output from the two radiometers by deducting the background radiation recorded from 5 s to 10 s after the moment of complete extinction.

Determine the average value of the two radiometers.

Determine the average value of time of recorded radiation during the 25 s period beginning at 30 s before the start of the foam application and ending 5 s before the start of foam application (see Figure J.2).

Determine the relative radiation by dividing the output by the average value obtained in accordance with the preceding paragraph.

The instantaneous radiation values are subject to random fluctuation. A smoother curve, which facilitates interpretation, can be obtained by plotting radiation values averaged over a period of  $\pm 5$  s for each time value.


The adjusted relative radiation is shown for the extinguishing test in Figure J.3 and for the burn-back test in Figure J.4. A control of 90 % is equivalent to the relative radiation 0,1.

The description above implies that computer-controlled measuring practices should be applied.

---

3) The Medtherm Series 64 supplied by Medtherm Corp., PO Box 412, Huntsville, AL, USA is an example of suitable apparatus available commercially. This information is given for the convenience of users of this part of ISO 7203 and does not constitute an endorsement by ISO of this apparatus.






**Key**

X time, expressed in minutes

Y radiation, expressed in kilowatts per square metre

NOTE Foam application starts at 1 min and stops at 5 min. The burn-back test starts at 15 min.

**Figure J.2 — Typical absolute radiation levels throughout a test**




**Key**

X time, expressed in minutes

Y relative radiation, dimensionless

NOTE Foam application starts at 0 min and stops at 4 min. 90 % control is achieved at about 1 min 8 s.

**Figure J.3 — Typical relative radiation levels during extinction**



**Key**

X time, expressed in minutes

Y relative radiation, dimensionless

NOTE Burn-back starts at 0 min. 25 % burn-back is at about 8 min 30 s.

**Figure J.4 — Typical relative radiation levels during burn-back**

## **Annex K** **(informative)**

### **Compatibility**

#### **K.1 Compatibility between foam concentrates and fire extinguishing powders**

Where foam and powder can be applied simultaneously or successively, users should ensure that any unfavourable interaction does not cause an unacceptable loss of efficiency.

#### **K.2 Compatibility between foam concentrates**

Foam concentrates of different manufacture, grade or class are frequently incompatible and should not be mixed, unless it has first been established that an unacceptable loss of efficiency does not result.

## Bibliography

- [1] ISO 5923, *Fire protection — Fire extinguishing media — Carbon dioxide*
- [2] ISO 6183, *Fire protection equipment — Carbon dioxide extinguishing systems for use on premises — Design and installation*
- [3] ISO 7076-1, *Fire protection — Foam fire extinguishing systems — Part 1: Foam proportioning equipment*
- [4] ISO 7201-1, *Fire protection — Fire extinguishing media — Halogenated hydrocarbons — Part 1: Specifications for halon 1211 and halon 1301*
- [5] ISO 7201-2, *Fire extinguishing media — Halogenated hydrocarbons — Part 2: Code of practice for safe handling and transfer procedures of halon 1211 and halon 1301*
- [6] ISO 7202, *Fire protection — Fire extinguishing media — Powder*
- [7] NORDTEST Method NT Fire 023, *Fire Extinguishing Foam Concentrates*



---

---

**ICS 13.220.10**

Price based on 38 pages